



全漢企業股份有限公司
FSP TECHNOLOGY INC.

台灣桃園市桃園區建國東路22號 統一編號：84239055
No. 22, Jianguo E. Rd., Taoyuan Dist., Taoyuan City 330, Taiwan (R.O.C)
TEL:+886-3-375-9888 Website:www.FSP-group.com
FAX:+886-3-375-6966 Email:sales@fsp-group.com.tw

SPECIFICATION



ESD16040699

FSP50-5000HD 220.898-02

Released Date:2016/08/02-18:09:45



全漢企業股份有限公司

FSP TECHNOLOGY INC.

台灣 桃園市建國東路 22 號

NO.22, Jianguo East Rd., Taoyuan City, Taiwan, R.O.C.

TEL:+886-3-375-9888 FAX:+886-3-375-6966

SPECIFICATION

FSP50-5000HD

R&D	CHECK	APPROVED	REV.
Along	M.H	H.B	X1

1. SCOPE

The FSP50-150327HD is a 50 watts isolated power supply with single output constant current and auto dimming. It could be used in LED lighting products.

2. FEATURE

All products delivered will meet all the requirements as outlined in the document. The basic requirements of the design features are listed below:

- * Output (Vf) forward voltage: 50 ~ 100V
- * Build in constant current circuit.
- * Short circuit protection / power limiting/over voltage protection/over temperature protection.
- * High reliability

3. MECHANICAL REQUIREMENTS

3.1 Power Supply Dimension Constraints

447.4mm (L)* 78.4mm (W)* 66.0mm (H)

(For detail mechanical size, please check the outline drawing.)

3.2 Power Supply Connectors

Primary:

Pin number	Output Name
P1__L1	Line-1
P2__L2	Line-2
P3__N	Neutral
P5	N.C
P6	N.C
P7__+	DALI (Refer to IEC 60929)/1-10V
P8__-	DALI (Refer to IEC 60929)/GND

Secondary: CN3

Pin number	Output Name
1	SGND
2	LED+ (Connect to LED High) & V _{EXT}
3	R_Code & Rx
4	LED- (Connect to LED Return)
5	NTC & Tx

4. ELECTRICAL REQUIREMENTS

4.1 Input AC

4.1.1 Input Voltage

Minimum	Nominal	Maximum	Unit
198	230	264	V _{AC}

4.1.2 Input Frequency

Minimum	Nominal	Maximum	
47	50/60	63	Hz

4.1.3 Input Power Factor

0.98, @ 198Vac input & full load.
 0.95, @ 230Vac input & full load.
 0.90, @ 264Vac input & full load.

4.2 DC Output

4.2.1 Output Currents and Loads

They are measured at the load end of connected cables.

Table.1 SMPS load limits

Signal Name	Constant Current (mA)			Voltage (V)		
	I min.	I normal	I max.	V min.	V typ.	V max.
Output for LED forward	532	560	588	50.0	80.0	100.0

Note: The no load output voltage should be less than 120V at any AC input condition.

Table.2 Current range

Dimming Signal	100%			10%		
	I min.	I normal	I max.	I min.	I normal	I max.
Chroma 6300 serial LEDL mode (mA)	532	560	588	52	56	60

4.3 Protection

4.3.1 Short Circuit Protection

DC output shall have short circuit protection. A short condition on any of DC outputs shall cause no damage to the power supply and shall have output short current $\leq 5A$ rms.

4.3.2 Fuse Protection

The fuse inside the power supply shall open when the AC input current is over the rated current of fuse. This fuse protection will cause switching power supply to fail.

4.3.3 Over Voltage Protection

Output voltage <160V, when output feedback system is abnormal.

4.4 Efficiency

90% typical. (It will be measured at the full load / nominal line / 25°C and after warm stable.)

4.5 Life

EC-Cap. Design Life : 50,000 hours. @230Vac & full load & ambient 25°C.

5. ENVIRONMENTAL REQUIREMENTS

5.1 Operating Temperature

Operating -40°C to + 55°C

Storage -40°C to + 70°C

Note : Thermal test must be done at nom. AC and at LED typical load.

5.2 Humidity (Non-condensing)

Operating 20% to 85% RH

Storage 10% to 95% RH

5.3 Hi-pot Test

Primary to Secondary : 3000VAC/ 1 minute & working current < 5.0mA .

5.4 Insulation Test

Insulation resistance : Primary to Secondary: 500Vdc, 25 M ohms min.

5.5 Leakage Current Test

Leakage current : Measured at 240Vac,50Hz, 0.25mA max.

6. INTERNATIONAL STANDARDS

6.1 EMI Standards

Designed to meet the following conducted limits:

EN55015

(Radiation must be tested with LED lighting.)

6.2 EMS Standards

6.2.1 Electrostatic Discharge Immunity Test : IEC-61000-4-2 Contact 4KV & Air 8KV, Criteria B

6.2.2 EFT/Burst Immunity Test: IEC-61000-4-4 4KV, Criteria B

6.2.3 Surge Immunity Test: IEC-61000-4-5 10KV, Criteria B

The spec. change list

Item	Revision	Descriptions	Date
1	X1	Initial spec. release	2016/07/26